

CONSTRUCTION OF MARALAL WATER SUPPLY PROJECT - PHASE I

QUESTIONS FROM BIDDERS

Date: 11th April 2024

S/No	QUERIES	ANSWERS
1	The amount of BOQ1-A420.2 is inconsistent with the sum described, please clarify	Quantity corrected to 22,200,000. Replace Page 90 with the newly attached/enclosed Page Numbered 90-Revised which incorporates this amendment
2	The amount package of BOQ1-A420.7 does not include the amount of 1-A420.5, please clarify.	Deleted accordingly from Item No. 1-A420.7 Replace Page 91 with the newly attached/enclosed Page Numbered 91-Revised which incorporates this amendment
3	Is the clay soil extraction sites, quarries and spoil sites are designated?	This will be instructed during the construction phase of the contract
4	What standard or quality grade the water reaches after treatment?	WHO/KEBS Standards
5	Could you kindly tell the source of funds for this project	The project is funded by the Government of Kenya
6	Where to get the construction water	The contractor to familiarize with the project area to determine the source of water and cost it in the rates
7	Could you please provide the geological report	The Works to be implemented as instructed by the consultant.