



NORTHERN WATER WORKS DEVELOPMENT AGENCY

Tel: 046-2103598
Fax: 046-2103197
E-mail: info@nwwda.go.ke

www.nwwda.go.ke

MAJI HOUSE
KISMAYU ROAD
P. O. BOX 495-70100, GARISSA

Ref: No. NWWDA/ACCTS/13 Vol.XIV(94)

Date: 17th February 2026

TO: ALL BIDDERS

RE: CLARIFICATION – TENDER NO. NWWDA/T/CW/002/2025-2026 (LOT 3)

A request for clarification has been received from one of the bidders regarding **BoQ Part 3.4 – 200m³ Steel Elevated Tank on a 12m Platform at Ijara Primary School.**

The bidder noted that Item No. A219.1 provides for the design of a 200m³ steel tank on a 15m platform, including foundation details, and that Item No. Z24 also references a 15m platform. Clarification was therefore sought on the correct tower height.

Northern Water Works Development Agency Response:

The height of the tank tower under Items A219.1 and Z24 is hereby corrected to **12 metres**, not 15 metres. Accordingly, all rates and prices submitted by you against the respective items shall be deemed to apply to a **12-metre-high tower.**

Eng. Collins Owiti
FOR CHIEF EXECUTIVE OFFICER